





CITEL

PV-DC-Junction box

GAK2.K2x10.K1x10.DP6-1-XS



- › Generator junction box for 2 MPP trackers / 2 strings
- › Integrated surge protection (type 1+2+3 - DPVN1-6C-21Y-1200)
- › Protection class IP65
- › Connection via spring-loaded terminals



| Electrical Characteristics | | |
|-------------------------------|-------|--|
| SPD type | IEC | 1+2+3 |
| Network | | PV network 1000 Vdc |
| Nominal DC voltage | Un-dc | 1000 Vdc |
| Rated insulation voltage | Ui | 1000 Vdc |
| Rated current | InA | 32 A |
| Rated string current | InC | 16 A |
| Mechanical Characteristics | | |
| Dimensions | | See diagram |
| Input / per MPPT | | Spring terminals / 2x 6-10 mm ² |
| Output / per MPPT | | Spring terminal / 1x 6-10mm ² |
| Ground connection terminal | | Screw terminal 6-35mm ² |
| Cable gland | | 14x M16 (Ø 4,5-10 mm) |
| Housing material | | UV and ozone resistant, fiberglass reinforced polycarbonate with semi-transparent cover |
| Dimensions | | WxHxD (mm): 254 x 180 x 111 |
| Ambient temperatures | | Indoor: -5°C to max. +40°C (+35°C 24h average) / Outdoor: -25°C to max. +40°C (+35°C 24h average) |
| Humidity | | Indoor: max. 50% at +40°C, max. 90% at 20°C (non-condensing) / Outdoor: 95% for a short time at +25°C (non-condensing) |
| Protection rating | | IP 65 |
| Protection class | | Class II |
| Impact resistance | | IK 8 |
| Pressure compensation element | | Existing |
| Standards | | |
| Standards compliance | | DIN EN 50539-11 / DIN EN IEC 61439-2 |
| Part number | | |
| 157208 | | |

