

EU Declaration of conformity

 ϵ

Company: CITEL

Address: 2, rue Troyon 92310, Sèvres, France

Trade Mark: CITEL

Products: Type 2 (or 3) SPD for AC network

This is to certify that **DSLP/DLPM series**, as follow, products manufactured by Citel are in compliance with:

- Directive 2011/65/EU (and delegated directive 2015/863/EU) on the Restriction of the use Of certain Hazardous Substances in electrical and electronic equipment (RoHS Directive).
- Low Voltage Directive 2014/35/EU, of the Council of the European Union

Models	Application
DSLP1-120L	Type 2 (or 3) SPD – For LED lighting system – Class I for 120 Vac Network
DSLP1-120L/Y	Type 2 (or 3) SPD – For LED lighting system – Class I for 120 Vac Network
DSLP1-230L	Type 2 (or 3) SPD – For LED lighting system – Class I for 220/240 Vac Network
DSLP1-230L/Y	Type 2 (or 3) SPD – For LED lighting system – Class I for 230/277 Vac Network
DSLP2-230L	Type 2 (or 3) SPD – For LED lighting system – Class II for 220/240 Vac Network
DLPM1-230L	Type 2 (or 3) SPD – For LED lighting system – Class I for 220/240 Vac Network
DLPM1-230L/Y	Type 2 (or 3) SPD – For LED lighting system – Class I for 230/277 Vac Network

2 rue Troyon, 92316 Sèvres CEDEX – FRANCE – Phone : +331 41 23 50 23 Email : contact@citel.fr – Website : http://www.citel.fr



The DSLP/DLPM series is in compliance with their related European testing standard:

European standard	Description
EN 61643-11:2012 EN 61643-11:2012/A11: 2018	Low-voltage surge protective devices – Part 11: Surge protective devices connected to low-voltage power systems - Requirement and test methods.
EN 61643-21:2001 EN 61643-21:2001/A1:2009 EN 61643-21:2001/A1:2013	Low-voltage surge protective devices – Part 21 Surge protective devices connected to telecommunications and signalling networks - Performance requirements and testing methods.

H.GUICHARD General Manager 2021-05-24

Authorized signatory for CITEL 2CP

P. Guillaumin Quality Manager 2021-05-24

CITEL 2 CP S.A.S.

Capital 5 013 500 €
2 rue Troyon

92316 SEVRES CEDEX
Tél.: 01 41 23 50 23
Fax: 01 41 23 50 09

Siren 387 740 095 - APE 27122