

EU Declaration of conformity

 ϵ

Company: CITEL

Address: 2, rue Troyon 92310, Sèvres, France

Trade Mark: CITEL

Products: Type 1+2+3 SPD for AC Network

This is to certify that **DAC1-13VG series**, as follow, products manufactured by Citel are in compliance with:

- Directive 2011/65/EU (and delegated directive 2015/863/EU) on the Restriction of the use Of certain Hazardous Substances in electrical and electronic equipment (RoHS Directive).
- Low Voltage Directive 2014/35/EU, of the Council of the European Union

Models	Application
DAC1-13VG-10-150	1-Pole Type 1 + 2 + 3 SPD for 120/208 Vac Network
DAC1-13VG-10-275	1-Pole Type 1 + 2 + 3 SPD for 230/400 Vac Network
DAC1-13VG-10-320	1-Pole Type 1 + 2 + 3 SPD for 230/400 Vac Network
DAC1-13VG-10-400	1-Pole Type 1 + 2 + 3 SPD for 230/400 Vac Network
DAC1-13VGS-10-150	1-Pole Type 1 + 2 + 3 SPD for 120/208 Vac Network (with remote signal)
DAC1-13VGS-10-275	1-Pole Type 1 + 2 + 3 SPD for 230/400 Vac Network (with remote signal)
DAC1-13VGS-10-320	1-Pole Type 1 + 2 + 3 SPD for 230/400 Vac Network (with remote signal)
DAC1-13VG-20-150	Single Phase Type 1 + 2 + 3 SPD for 120 Vac Network
DAC1-13VG-20-275	Single Phase Type 1 + 2 + 3 SPD for 230 Vac Network
DAC1-13VG-20-320	Single Phase Type 1 + 2 + 3 SPD for 230 Vac Network
DAC1-13VG-20-400	Single Phase Type 1 + 2 + 3 SPD for 230 Vac Network
DAC1-13VGS-20-150	Single Phase Type 1 + 2 + 3 SPD for 120 Vac Network (with remote signal)
DAC1-13VGS-20-275	Single Phase Type 1 + 2 + 3 SPD for 230 Vac Network (with remote signal)
DAC1-13VGS-20-320	Single Phase Type 1 + 2 + 3 SPD for 230 Vac Network (with remote signal)
DAC1-13VG-11-150	Single Phase Type 1 + 2 + 3 SPD for 120 Vac Network

2 rue Troyon, 92316 Sèvres CEDEX – FRANCE – Phone : +331 41 23 50 23 Email : contact@citel.fr – Website : http://www.citel.fr



Models	Application
DAC1-13VG-11-275	Single Phase Type 1 + 2 + 3 SPD for 230 Vac Network
DAC1-13VG-11-320	Single Phase Type 1 + 2 + 3 SPD for 230 Vac Network
DAC1-13VGS-11-150	Single Phase Type 1 + 2 + 3 SPD for 120 Vac Network (with remote signal)
DAC1-13VGS-11-275	Single Phase Type 1 + 2 + 3 SPD for 230 Vac Network (with remote signal)
DAC1-13VGS-11-320	Single Phase Type 1 + 2 + 3 SPD for 230 Vac Network (with remote signal)
DAC1-13VG-30-150	3-phase Type 1 + 2 + 3 SPD for 120/208 Vac Network
DAC1-13VG-30-275	3-phase Type 1 + 2 + 3 SPD for 230/400 Vac Network
DAC1-13VG-30-320	3-phase Type 1 + 2 + 3 SPD for 230/400 Vac Network
DAC1-13VG-30-400	3-phase Type 1 + 2 + 3 SPD for 230/400 Vac Network
DAC1-13VGS-30-150	3-phase Type 1 + 2 + 3 SPD for 120/208 Vac Network (with remote signal)
DAC1-13VGS-30-275	3-phase Type 1 + 2 + 3 SPD for 230/400 Vac Network (with remote signal)
DAC1-13VGS-30-320	3-phase Type 1 + 2 + 3 SPD for 230/400 Vac Network (with remote signal)
DAC1-13VG-40-150	3-phase + N Type 1 + 2 + 3 SPD for 120/208 Vac Network
DAC1-13VG-40-275	3-phase + N Type 1 + 2 + 3 SPD for 230/400 Vac Network
DAC1-13VG-40-320	3-phase + N Type 1 + 2 + 3 SPD for 230/400 Vac Network
DAC1-13VG-40-400	3-phase + N Type 1 + 2 + 3 SPD for 230/400 Vac Network
DAC1-13VGS-40-150	3-phase + N Type 1 + 2 + 3 SPD for 120/208 Vac Network (with remote signal)
DAC1-13VGS-40-275	3-phase + N Type 1 + 2 + 3 SPD for 230/400 Vac Network (with remote signal)
DAC1-13VGS-40-320	3-phase + N Type 1 + 2 + 3 SPD for 230/400 Vac Network (with remote signal)
DAC1-13VG-31-150	3-phase + N Type 1 + 2 + 3 SPD for 120/208 Vac Network
DAC1-13VG-31-275	3-phase + N Type 1 + 2 + 3 SPD for 230/400 Vac Network
DAC1-13VG-31-320	3-phase + N Type 1 + 2 + 3 SPD for 230/400 Vac Network
DAC1-13VGS-31-150	3-phase + N Type 1 + 2 + 3 SPD for 120/208 Vac Network (with remote signal)
DAC1-13VGS-31-275	3-phase + N Type 1 + 2 + 3 SPD for 230/400 Vac Network (with remote signal)
DAC1-13VGS-31-320	3-phase + N Type 1 + 2 + 3 SPD for 230/400 Vac Network (with remote signal)



The DAC1-13VG series is in compliance with their related European testing standard:

European standard	Description
EN 61643-11:2012 EN 61643-11:2012/A11: 2018	Low-voltage surge protective devices – Part 11: Surge protective devices connected to low-voltage power systems - Requirement and test methods.

H.GUICHARD General Manager 2021-05-24

Authorized signatory for CITEL 2CP

P. Guillaumin Quality Manager 2021-05-24

CITEL 2 CP S.A.S.
Capital 5 013 500 €
2 rue Troyon
92316 SEVRES CEDEX
Tél.: 01 41 23 50 23
Fax: 01 41 23 50 09
Siren 387 740 095 - APE 27122