

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Surge protective devices in photovoltaic applications
Name and address of the applicant	CITEL SAS 29 boulevard Edgar Quinet, 75014 Paris, France
Name and address of the manufacturer	CCSH Manufacturing Co., LTD. 499, Kangyi Road, Kang Qiao Industrial Zone, 201315 Shanghai, China
Name and address of the factory	CCSH Manufacturing Co., LTD. 499, Kangyi Road, Kang Qiao Industrial Zone, 201315 Shanghai, China
<i>When more than one factory</i>	<input type="checkbox"/> <a href="#">Additional information on page 2</a>
Ratings and principal characteristics	<b>Product data</b> Ratings: Test class II/Type 2 & Test class III/Type 3; IP20 Ucpv: 600/850/1200/1500 Vdc; In: 20 kA; I <sub>max</sub> : 40 kA; I <sub>scpv</sub> : 15 kA; Uoc: 6 kV; Up: 2.3/3.3/4.3/4.8 kV
Trademark / Brand (if any)	 CITEL
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	DPVN40CVG-21Y-1200, DPVN40CVG-21Y-1500, DPVN40CVG-21Y-600, DPVN40CVG-21Y-850, DPVN40CVGS-21Y-1200, DPVN40CVGS-21Y-1500, DPVN40CVGS-21Y-600 and DPVN40CVGS-21Y-850
Additional information	<input type="checkbox"/> <a href="#">Additional information on page 2</a>
A sample of the product was tested and found to be in conformity with	IEC 61643-31:2018  <b>National differences:</b> EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6189342.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
6825 MJ Arnhem  
Netherlands

Date: 2024-05-29

Signature: May Liu