

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Surge Protective Devices
Name and address of the applicant	CITEL SAS 29 boulevard Edgar Quinet, 75014 Paris, France
Name and address of the manufacturer	CCSH Manufacturing Co., LTD. 499, Kangyi Road, Kang Qiao Industrial Zone, 201315 Shanghai, China
Name and address of the factory	CCSH Manufacturing Co., LTD. 499, Kangyi Road, Kang Qiao Industrial Zone, 201315 Shanghai, China
<i>When more than one factory</i>	<input type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	Product data Ratings: Test class I/Type 1 & Test class II/Type 2 & Test class III/Type 3; Uc: 275 Vac; Iimp: 25 kA; In: 25 kA(L-N), 100 kA(N-PE); Imax: 100 kA(L-N, N-PE); Uoc: 6 kV; Up: 1.5 kV; IP20
Trademark / Brand (if any)	 CITEL
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	DACN1-25CVGS-11-275, DACN1-25CVGS-11-275/SC, DACN1-25CVGS-31-275 and DACN1-25CVGS-31-275/SC
Additional information	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61643-11:2011 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6213070.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2025-04-02

Signature: May Liu