


DS50PVS-1000/12KT1



- Type 1+2 surge protector for Photovoltaic
- Impulse currents Iimp/Itotal: 6.25/12.5 kA (10/350µs)
- Common/Differential mode protection
- Remote signaling
- UL1449 ed.5 compliance
- IEC 61643-31, EN 61643-31 certify





V: High-energy varistor
Ft: Thermal fuse
C: Remote signal contact
t°: Thermal disconnection system
MI: Disconnection indicator

Electrical Characteristics		
SPD type	IEC	1+2
Network		PV network 1000 Vdc
Nominal PV voltage	Uocstc	1000 Vdc
Max. PV operating voltage	Ucpv	1200 Vdc
Residual Current *Leakage current to Ground*	Ipe	None
PV Permanent Operating current *Current consumption at Ucpv*	Icpv	< 0.1 mA
Follow current	If	None
Nominal discharge current *15 x 8/20 µs impulses*	In	15 kA
Max. discharge current *max. withstand @ 8/20 µs by pole*	Imax	40 kA
Impulse current by pole *max. withstand 10/350µs by pole*	Iimp	6.25 kA
Total lightning current *max. total withstand @ 10/350µs*	Itotal	12.5 kA
Current withstand short circuit PV	Iscpv	15 000 A
Connection mode(s)		+/-/PE
Protection mode(s)		Common/Differential mode
Protection level +/- *@ In (8/20µs)*	Up	4.8 kV
Protection level +/PE (-/PE) *@ In (8/20µs)*	Up	4.2 kV
Mechanical Characteristics		
Technology		MOV
Connection to Network		By screw terminals: 2.5-25mm²
Format		Plug-in modular box
Mounting		Symmetrical rail 35 mm (EN 60715)
Housing material		Thermoplastic UL94 V-0
Operating temperature	Tu	-40/+85°C
Protection rating		IP20
Disconnection indicator		3 mechanical indicators
Spare module(s)		DSM50PV-1000/12KT1 + DSM50PV-1000PE/12KT1
Remote signaling of disconnection		Output on changeover contact
Dimensions		See diagram
Disconnectors		
Thermal disconnector		Internal
Back-up protection device		Without
Standards		
Standards compliance		IEC 61643-31 / EN 61643-31 / EN 50539-11 / UL1449 ed.5
Certification		TUV
Part number		
482371		