





Type 2 AC surge protector - Single-phase

CITEL

DS42S-120



- Type 2 AC Multipolar surge protector
- In : 20 kA
- Imax total : 80 kA
- Pluggable module for each phase
- Remote signaling
- NF EN 61643-11, IEC 61643-11 compliance
- UL1449 ed.50



V: High-energy varistor
Ft: Thermal fuse
C: Remote signal contact
 t° : Thermal disconnection system
MI: Disconnection indicator

Electrical Characteristics	
SPD type	2
Network	120 V single-phase
AC system	TN
Nominal line voltage	Un 120 Vac
Max. AC operating voltage	Uc 150 Vac
Temporary Over Voltage (TOV) Characteristics - 5 sec. Without disconnection	UT 180 Vac withstand
Temporary Over Voltage (TOV) Characteristics - 120 mn Without disconnection or with safety disconnection	UT 230 Vac disconnection
Residual Current Leakage current to Ground	Ipe < 1 mA
Follow current	If None
Nominal discharge current 15 x 8/20 μ s impulses	In 20 kA
Max. discharge current max. withstand @ 8/20 μ s by pole	Imax 40 kA
Connection mode(s)	L/PE and N/PE
Protection mode(s)	Common mode
Residuel voltage at 5 kA @ 5 kA (8/20 μ s)	Up-5kA 0.6 kV
Protection level N/PE @ In (8/20 μ s)	Up N/PE 0.9 kV
Protection level L/PE @ In (8/20 μ s)	Up L/PE 1.2 kV
Admissible short-circuit current	Isccr 25 000 A
Mechanical Characteristics	
Technology	MOV
SPD configuration	Single phase
Connection to Network	By screw terminals: 2.5-25mm ² / by bus
Format	Plug-in modular box
Mounting	Symmetrical rail 35 mm (EN 60715)
Housing material	Thermoplastic UL94 V-0
Operating temperature	Tu -40/+85°C
Protection rating	IP20
Failsafe mode	Disconnection from AC network
Disconnection indicator	1 mechanical indicator by pole
Spare module(s)	DSM40-120
Remote signaling of disconnection	Output on changeover contact
Dimensions	See diagram
Disconnectors	
Thermal disconnector	Internal
Installation ground fault breaker	Type 'S' or delayed
Back-up protection device	Fuses type gG - 50 A
Standards	
Standards compliance	IEC 61643-11 / EN 61643-11 / UL1449 ed.5
Certification	CSA / UL Listed
Part number	461621

